



किंग जार्ज चिकित्सा विश्वविद्यालय उत्तर प्रदेश, लखनऊ कार्यालय अधिशासी अभियन्ता (विद्युत/यांत्रिक)

पत्रांक : 121 / ई0ई0(ई/एम.)

Urgent Quotation Notice

दिनांक : 19/04/24

Sub:- Replacement of burnt out TPN main switch & busbar at Forensic Medicine Department, KGMU, Lko.

Sir,

Sealed quotations are invited here by the reputed firms/electrical contractors for the following items in sealed envelope to the undersigned **in the interest of patient care/ institution** with in 3 days from the date of calling quotation :-

Sl. No.	Particulars of Work	Qty.	Rate	Amount in Rs.
1.	S/F of MCCB 200Amp. 4 pole as per ps.no. 1021 (f)	01 No.		
2.	S/F of busbar 200Amp. Capacity with copper strip terminals, nut-bolt etc. complete in all respect.	01 No.		
3.	S/F of lugs 70sq.mm. as per ps. no. 504 (h)	09 Nos.		
4.	S/F of lugs 35sq.mm. as per ps. no. 504 (f)	03 Nos.		
5.	S/F of MCCB enclosure for 200Amp. 4 pole MCCB	01 No.		
6.	Dismantling charges of burnt out TPN & busbar and removing carbon of incoming & outgoing lead with restoration of electricity complete in all respect.	01 Job.		
G. Total Rs.				

Terms & Conditions:-

- G.S.T. extra as applicable.
- All the works shall be completed within the given time period (as per work order).
- Quantity may be increase or decrease as per requirements at site and payment shall be made accordingly.
- All the works shall be carried out as per PWD specifications.
- Payment shall be made after satisfactory completion of above works through Finance office only.
- Contractor having experience of similar nature and style electrical work in 300 bedded Govt./Semi Govt. Hospital.

Your's Faithfully

Executive Engineer (Electrical)
K.G.M.U.U.P., LUCKNOW.

No. _____ of Dt. _____

Copy for information and necessary action to:-

- Dr. Richa Khanna, Faculty In-charge, Website Administration Data Center, PHI Bhawan, KGMU for uploading the Quotation Notice in KGMU. Website from _____
- Notice board.

Executive Engineer (Electrical)
K.G.M.U.U.P., LUCKNOW.

No. _____ of Dt. _____

Copy for _____